

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01

Dated: 18/06/2026

It is certified that an inspection team headed by **Suresh S Panchal**, Assistant Executive Engineer Inspected the **Shri Prabhulingeshwar International School, Chimmad**. on 18-06-2026 and on the basis of Water Test Report (Attached) bearing no. **JKD2026JUN0003** dated. 18/06/2026 of RDW & SD Sub Division Jamkhandi certified that the **Shri Prabhulingeshwar International School, Chimmad**. has a safe drinking water facility for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till Three years only

To
**Shri Prabhulingeshwar
International School,
Chimmad**
(Name & Address of the Institution)

Signature with Seal :

**Assistant Executive Engineer
R.D.W.S.&S.
Sub-Division, JAMKHANDI.**

Name : Suresh S Panchal

Designation : Assistant Executive Engineer

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
RURAL WATER SUPPLY & SANITATION SUB- DIVISION LABORATORY
 Maigur road , Near Bharat petrol pump, Kankanwadi RC, Jamkhandi-587301
 e-mail:rdwsd.wqmbspjamkhandilab@gmail.com

TEST REPORT

Location : Shri Prabhulingeshwar International School Near Prabhulingeshwar temple G P : Chimmad Taluka : Rabakavi-Banahatti District : Bagalkot			Report date	:	18-06-2026
			Report Number	:	JKDJUN003
			Reference	:	Sample receipt Form
			Sample receipt date	:	17-06-2026
			Sample code	:	JKD2026JUN003
			Date of Sample Collection	:	17-06-2026
			Analysis start date	:	18-06-2026
			Analysis completion date	:	18-06-2026
Sample collection protocol			:	IS10500:2012	
Sample Particulars: RO			Sample quantity	:	1000ml
Sl.No	Test	Results	Acceptable Limit is 10500 :2012	Permissible Limit is 10500 :2012 RA:2018	Protocol
1	pH Value @Temp 25±2°C	6.64	6.5-8.5	No Relaxation	IS 3025 (part-11) :2022
2	Specific Conductance, µS/cm @Temp 25±2°C	43	-	-	IS 3025 (part-14) :2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (part-5) :2018
4	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (part-8) :2023
5	Colour, Hazen Units	<5	5	15	IS 3025 (part-4) :2021
6	Turbidity ,NTU	0.1	1	5	IS 3025 (part-10) :2023
7	Total Dissolved Solids ,@180mg/l	23.9	500	2000	IS 3025 (part-16) :2023
8	Alkalinity as CaCO ₃ ,mg/l	4.33	200	600	IS 3025 (part-23) :2023
9	Total hardness as CaCO ₃ ,mg/l	14.99	200	600	IS 3025 (part-21) :2009
10	Calcium as Ca,mg/l	1.50	75	200	IS 3025 (part-40) :2024
11	Magnesium as Mg,mg/l	2.73	30	100	IS 3025 (part-46) :2023
12	Chloride as Cl,mg/l	3.86	250	1000	IS 3025 (part-32) :2025
13	Sulphate as SO ₄ ,mg/l	1	200	400	IS 3025 (part-24, Sec.1) :2022 Method.a
14	Fluoride as F ,mg/l	0.22	1	1.5	APHA 24rd Edition:4500F-D
15	Nitrate as NO ₃ ,mg/l	14.08	45	No Relaxation	APHA 24rd Edition:4500NO3-B
16	Iron as Fe ,mg/l	0.03	1	No Relaxation	IS 3025 (part-53) :2024 Method.a
Remarks: The given sample conforms to the Acceptable limits of IS:10500:2012 RA2018 Drinking water specification for above tested physical & Chemical parameters only.					

RDWSD/WQMSP/TeR/1

Analysed By: 
 Analyst


 Authorised Signatory S S Panchal
 Assistant Executive Engineer

Note:

- 1) The above sample brought by the customer
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) The Traceability : Traceability of measurements is established using CRM's traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in the RDWSD/WQMSP/DR-01.